



ABN:17-949-415-002

Advanced Material Technologies

Providing Solutions, Delivering Results!



Since 2000

News Bulletin

Superior Water Conditioners to prevent water tube failures and their effect on corrosion

We have been promoting to the Australian Boiler owners and maintenance services, Chemical plants, Oil Refineries, Mineral Processing, Metallurgical industry the new and innovative **Superior Water Conditioners**.

The water conditioning is aimed at issues where lime scale, fouling and air leakage in steam condensers, cooling towers, water reclamation plants, boiler water lines affects plant efficiency where water is a vital part of the operation.

The loss on heat transfer can be quite serious and cost the plant hundreds of thousands of dollars or more if a problem occurs during a peak generating period or becomes a long term event.

Internal Tube Deposits

Deposits on the internal of water tubes can set up a nightmare scenario. In the first place, deposits might initiate corrosion by establishing differential oxygen cells where the area underneath the deposit or buildup becomes anodic to the exposed metal.

To explain further, the formation of small anodes in a large cathode environment generates the most insidious types of corrosion – pitting – in which a small metal loss by weight can result in through wall penetrations and reduce flow rates from hard scale (calcite) buildup.

Now with the **Superior water conditioners** the hard-scale deposit currently experienced is now reduced to a softer aragonite talc material simply by changing the ionic structure of the water through an induced magnetic field of **Superior Water Conditioners**.

Hence, when hard scale is the deposition material, oxygen differential scale is possible but if the deposit is porous in nature impurities in the water like (Cl) chlorides and sulphates (SO₄) can concentrate under the deposit and further exacerbate the corrosion mechanism. This is quite common with carbon steels.

28 Charlton Street Mt. Warrigal NSW. 2528. Australia. E-mail: john.pulbrook@bigpond.com

Phone: 0242 956915

Mobile: 0450 695691

Skype: johnpulbrook1

www.advancedmaterialtechnologies.com



Advanced Material Technologies

Providing Solutions, Delivering Results!

ABN:17-949-415-002



Since 2000

The Upshot of these issues and why Superior Water Conditioners should be installed


Cooling water from a lake or river typically contains a few hundred ppm of anions and cations, most notably calcium, sodium, magnesium, potassium, bicarbonate, chloride, silica and sulphate, as well as other elements, including suspended solids.

In cooling towers, these impurities cycle up in concentration. As these contaminants enter the boiler, a number of temperature induced reactions occur. Two common reactions are shown;


- $\text{Ca}^{2+} + 2\text{HCO}_3^- = \text{CaCO}_3 + \text{CO}_2 + \text{H}_2\text{O}$
- $\text{Ca}^{2+} + (\text{or Mg}^{2+}) + \text{SiO}_3^{2-} = \text{CaSiO}_3 + (\text{or MgSiO}_3)$

These are scale formation reactions that Superior water conditioners will prevent from occurring. These reactions causing a thin deposit on the internals of steel pipes will significantly reduce heat transfer and a boiler must be fired harder to achieve the same level of steam production. This also can lead to overheating of the boiler tubes which will shorten boiler tube life adding to the maintenance cost.

Much more frightening is the effect that cooling water in-leakage has with regard to rapid and catastrophic corrosion. The reaction shown below is a prime example:-



Magnesium salts react with water to produce magnesium hydroxide precipitate plus hydrochloric acid. While hydrochloric acid may cause general corrosion in and of itself, the compound will concentrate under deposits where the reaction of acid with iron generates hydrogen which can lead to hydrogen damage of the boiler tubes. In this mechanism, hydrogen gas molecules which are very small, penetrate into the metal wall and react with carbon atoms in the steel to generate methane (CH_4).



Formation of the gaseous methane and hydrogen molecules will cause cracking in the steel, greatly weakening its strength.

After hydrogen damage has occurred, the plant engineers might replace tubes to find other tubes continue to rupture. Needless to say the up line mechanisms that may fail and are very unwelcome in a finely balanced piece of machinery that may cost millions to repair when in fact, all that was needed down line was the installation of Superior water conditioners.

28 Charlton Street Mt. Warrigal NSW. 2528. Australia. E-mail: john.pulbrook@bigpond.com

Phone: 0242 956915

Mobile: 0450 695691

Skype: johnpulbrook1

www.advancedmaterialtechnologies.com



ABN:17-949-415-002

Advanced Material Technologies

Providing Solutions, Delivering Results!



Since 2000

With the **Superior magnetic water conditioning** to alleviate the above described problems this will provide the following functions;

- Prevent scale deposition
- Descaling, recognizing that the descaling process is slow and may take several months to complete.
- Corrosion control.
- White rust control.

Magnetic water conditioners have been employed in over 300,000 applications. Their operation is characterized by:

- Minimal maintenance.
- Slight pressure drop.
- Absence of chemical additions, and therefore no environmental effects.
- Indefinite service life.
- Easily integrated into existing applications.

This **non-chemical method** to control lime scale is not only used to increase quality in the product and reduce production costs but also as a means to reduce pollution and enhance the image of the industry.

SCALE & CORROSION

To conclude, water is the most frequently used media to transfer thermal energy for useful purposes. When water temperature changes, minerals precipitate and form a hard, brittle scale (calcite) that collects in piping and on heat transfer surfaces.

This insulating scale build-up reduces efficiency of equipment, increases the fuel use and will increase maintenance time and costs. When water passes through **Superior's alternating magnetic fields**, it allows the minerals to form in a suspended state as an amorphous powder which deposits a thin film of aragonite talc on the inside of pipes which is washed away; therefore eliminating the formation of hard, brittle scale and corrosion.

Maintaining scale-free surfaces assures optimum utilization of your equipment. Superiorized® water controls the formation of scale and corrosion deposits without the use of hazardous and costly chemicals. Because no chemicals are used, discharged water is pollution-free and is not harmful to the environment. Superior water treatment systems solve lime scale build-up problems, resulting in energy and water conservation and pollution prevention.

The following cross sectional cut-out provides an excellent illustration and description of how the **Superior Magnetic Water Conditioner** functions.

28 Charlton Street Mt. Warrigal NSW. 2528. Australia. E-mail: john.pulbrook@bigpond.com

Phone: 0242 956915

Mobile: 0450 695691

Skype: johnpulbrook1

www.advancedmaterialtechnologies.com




ABN:17-949-415-002

Advanced Material Technologies

Providing Solutions, Delivering Results!



Since 2000



SUPERIOR WATER CONDITIONER CROSS SECTIONAL VIEW

Written by: John Pulbrook - Director

28 Charlton Street Mt. Warrigal NSW. 2528. Australia. E-mail: john.pulbrook@bigpond.com

Phone: 0242 956915

Mobile: 0450 695691

Skype: johnpulbrook1

www.advancedmaterialtechnologies.com